



LEGEND

- EF-1 EXTRACT FAN TYPE 1 INCL. FLOW/HEAD
- SF-1 SUPPLY FAN TYPE 1 INCL. FLOW/HEAD
- RG EGG CRATE RETURN GRILLE, INCL DIMS
- 4 WAY SUPPLY GRILLE, INCL DIMS
- 3 WAY SUPPLY GRILLE, INCL DIMS
- IU-1 INDOOR A/C UNIT TYPE 1
- CASSETTE INDOOR A/C UNIT TYPE
- OU-1 OUTDOOR A/C UNIT TYPE 1
- MC MASTER CONTROLLER
- G3 FILTER TYPE G3
- FIRE BRIGADE MANUAL OVERRIDE SWITCH
- DIFFERENTIAL PRESSURE TRANSDUCER
- DOOR CONTACT SWITCH
- FD FIRE DAMPER
- FSD MOTORISED FIRE SMOKE DAMPER
- VCD CONSTANT VOLUME CONTROL DAMPER
- MCD MOTORISED CONTROL DAMPER
- 300X140/475 DUCT INTERNAL DIM. / FLOW m3/Hr
- POLYURETHANE 20mm OR GALV. STEEL
- SMOKE EXTRACT GALV STEEL DUCT

NOTES:

FINAL LOCATION OF DEVICES TO BE COORDINATED WITH OTHER SERVICES/CONSULTANT

REV	DESCRIPTION	DATE
Ing. Edwin Aquilina B. Mech. Eng. (Hons.) Eur Ing Engineering Consultancy Services Project Management Fire Safety Engineering Mob (+356) 99435668 E-Mail edwinaquilina@gmail.com		
Drawing Title: HEATING AND VENTILATION PLAN INTERMEDIATE, IMMACULATED CONCEPTION CHAPEL, TRIQ IL-KUNCIZZJONI MSIDA		
Drawing No: AC-11-021-22	Scale: 1:100 (A3)	
Project Ref: 021/22	Sheet: 1 of 1	
Drawn: IAa	Checked: EAa	Status: DESIGN
		Date: 26.01.2022
DIMENSIONS IN mm		