



Ing. Edwin Aquilina
P. O. Box 19, Head Office
Marsa

E-Mail: edwinaquilina@gmail.com

Mobile: 9943 5668

Supplied From: DB 1

Supply Cable: 3x10mm2 PVC

Incomer: MCB 2P 40A, watt hour meter

Metal Clad, 12 module

Location:

Intermediate Level

Reference:

DB 11

Way	Position	Prot.	Device	Cable	Description
	1	RCBO	DP 25A	3 x 4.0mm2 PVC	General Power
	2	RCBO	DP 25A	4 x 4.0mm2 PVC	Air Condition
	3	RCBO	DP 6A	3 x 1.5 mm2 PVC	Lights internal
	4	RCBO	DP 6A	3 x 1.5 mm2 PVC	Lights internal
	5	RCBO	DP 6A	3 x 1.5 mm2 PVC	Lights external