

---

**From:** Birkirkara SE Tender  
**Sent:** 04 March 2024 14:12  
**To:**  
**Cc:**  
**Subject:** Clarification questions - St Helen Basilica Tender

Good afternoon.

Below please find reply to clarification request of St Helen Basilica.

Please find our replies below:

1. DALI and 0/1-10V luminaires are both to be connected with 5 core cable. Is that correct? **Yes. All wiring between the distribution boards and the luminaire drivers on the church premises are to be connected with 5-core cables.**
2. Can we quote DALI luminaires when they are specified for 0/1-10V or vice versa? **No, as these would not be technically compliant.**
3. Cables from Demarcation both boxes to DALI luminaires are 3core and not 5core in the DB schedule. Are these correct? **Wiring from the demarcation boxes to DALI luminaires is a measurable quantity.**
4. Are all DBs interconnected or use of wireless BLE is required because there are some DBs that cannot be connected together? **The distribution boards installed within the church premises only are interconnected via the design wiring, as per tender dossier. All wiring is a measurable quantity.**
5. Do you require only 1 control switch, as listed in the BOQ? **Yes, only 1 control switch is required.**

Kind regards,  
Gail

**Gail Baldacchino**

Senior Clerk

Tel +356 25906 700

Email [gail.baldacchino@maltadiocese.org](mailto:gail.baldacchino@maltadiocese.org)

[www.church.mt](http://www.church.mt)

